

# Attestation

## LEED v4, v4.1 BETA, and v5 Extra Plus Matt

supplied by

### FSW Coatings Ltd

The sample of water-based paint was supplied to Eurofins Product Testing A/S on the 3<sup>rd</sup> of March 2026. The sample was tested as being representative of the manufactured product and it has been tested according to the relevant ISO 16000, EN 16516, and ASTM D2369 testing standards (See test report no. 392-2026-00120601\_A\_EN and no. 392-2026-00120602\_XG\_EN).

Deviations from the referenced test methods were registered. (See section 4.4 in test report no. 392-2026-00120601\_A\_EN).

**The test results of the tested sample indicate that the product qualifies for LEED v4, LEED v4.1 BETA (November 2025), and LEED v5 (November 2025) projects in Europe by showing compliance with the specifications for VOC emissions and VOC content by complying with:**

#### **VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:**

- The requirements of LEED v4.1 BETA (November 2025) and LEED v5 (November 2025) by complying with the German AgBB Testing and Evaluation Scheme (2024), showing an overall R-value  $\leq 1$ , having a TVOC according to EN 16516  $\leq 1,000 \mu\text{g}/\text{m}^3$ , a sum of VOC without LCI  $< 100 \mu\text{g}/\text{m}^3$ , and a formaldehyde emission  $\leq 10 \mu\text{g}/\text{m}^3$ ; all after 28 days.
- The requirements of LEED v4 and LEED v4.1 BETA by complying with:
  - The requirements of Indoor Air Comfort Gold v2026 (January 2026).

#### **VOC content specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:**

- The requirements of LEED v4 and LEED v4.1 BETA (November 2025): EU Decopaint Directive 2004/42/CE for 'Interior matt walls and ceilings, WB' having a VOC content below 30 g/L.

30 April 2026



Isabella B. Larsen  
Analytical Service Manager

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*